

ANNEX B: ITB BoQs Form							
		اتفاقية توريد وتركيب انابيب بولي إيثيلين عالي الكثافة في حضرموت (غيل باوزير) مناقصة رقم : ITB/ FMF/ADE200102/2025 Agreement to supply and install high-density polyethylene pipes in Hadramout districts (Ghayl Bawazeer)					
About the Field Medical Foundation: The Field Medical Foundation is a comprehensive community-based, non-profit, developmental organization that seeks to be a pioneer in humanitarian action through its health, relief, and development services, which aims to improve community health and build capacity through projects and services provided with high quality and high credibility.		نبذة عن المؤسسة الطبية الميدانية : المؤسسة الطبية الميدانية مؤسسة غير ربحية مجتمعية تنموية شاملة تسعى ان تكون رائدة في العمل الإنساني وذلك عبر خدماتها الصحية والإغاثية و التنموية والتي تهدف إلى تحسين صحة المجتمع وبناء القدرات من خلال المشاريع و الخدمات المقدمة ذات الجودة و المصداقية العالية .					
Tender no(s): رقم العطاء	ITB/ FMFADE200102/2025 /PR/FMF ADE 2025 101308		Bid date : تاريخ العطاء :	21/10/2025			
			Bid submission date : تاريخ تسليم العطاء من قبل المورد :	04/11/2025			
SUPPLIER Information : معلومات المورد			For any Informayion : FMF				
Company name / Trading name الاسم التجاري / اسم الشركة			Contact name الاسم :	Mofeed			
Contact person الشخص الذي يمكن الاتصال به			E-mail/ البريد	operation.dept@fmfyemen.org			
E-mail/ البريد			Phone / هاتف	02-233460 / 103			
Phone/ هاتف			Address/العنوان	الجمهورية اليمنية- محافظة عدن- خورمكسر- ساحل أبين- مقابل لرناسة جامعة عدن			
Mobile/ موبايل							
Items required by: Supplier							
Currency : All items must be in US Dollars			العملة : يتم تسعير الأصناف بالدولار الأمريكي				
Line item no.	Description	Specification	Unit	Qty	Unit price	Total price	Remark
1	Supplying and installing for pipeline of HDPE with diameter of 110mm – 16 par fulfilled with DIN8074/75 using hydraulic welding including all necessary parts , joints and accessories	HDPE pipe shall be manufactured from PE 100 material in accordance with DIN 8074/8075, SDR 11, rated for PN 16 bar. Minimum wall thickness shall be 10.0 mm. Pipes shall be joined by hydraulic butt fusion welding in compliance with ISO 21307 or equivalent. All fittings (bends, tees, reducers, couplers) shall conform to the same pressure rating and material class. Installation shall follow manufacturer's recommendations and applicable standards (ISO 4427 / EN 12201).	M	9700		0	
2	Supplying and installing for control gate valve of ductile iron with diameter of 110mm – 25 par fulfilled with DIN3202 including all necessary parts , adapters , joints , fixing bolts and accessories	ate valve shall be made of ductile cast iron (GGG 40 / GGG 50), designed and tested in accordance with DIN 3202 (face-to-face dimensions), DIN 3352 (design and materials), and EN 1074 (performance). Valve shall have a PN 25 bar pressure rating, EPDM resilient seat, fusion-bonded epoxy coating (min 250 µm) inside and outside. The valve shall include all necessary flanged adapters, bolts, nuts, gaskets, and joints, and be suitable for potable water service. Installation shall comply with manufacturer's specifications and project standards.	No	20		0	
						Total Price	0

Delivery Location : مكان التوصيل :		حضرموت (غيل باوزير)				
Timeline to complete all works after signing the contract : الجدول الزمني لانتهاء من العمل بعد توقيع العقد :						
Name of authorized representative of the Supplier:						
Signature and Stamp:						
Please provide last 3 references :			Phone Num:	Email :		
Reference 1:						
Reference 2:						
Reference 3:						