



MSF Médecins Sans Frontières [Yemen-Kilo-YE120]

Electrical Works

Technical Specifications Document

TECHNICAL SPECIFICATIONS, DESCRIPTION OF MATERIALS AND WORKMANSHIP FOR THE ELECTRICAL WORKS IN LOCAL CONSTRUCTION

The whole of the specifications contained in this section shall be read as incorporated in all subsequent sections of the Bills of Quantities and the contractor shall include in his rates for complying therewith.

It is assumed that the contractor's supervisory and estimating staff is fully conversant with the normal standards of good workmanship and relevant publications of trade and technical organizations.

This document directs the contractor to the relevant information necessary for pricing the Bills. It is therefore essential that the text contained therein be read in conjunction with the measured items which shall be priced accordingly.

Any specified material, product or service may be substituted only with the approval of the Project Manager/ Supervising Officers.

Should it occur that any part or parts of the drawings or specifications should not be clearly intelligible to the contractor, or that the materials or methods of execution to be used in the works be considered insufficiently described or inappropriate, then the Project Manager/ Supervising Officers shall be requested in writing, to make clear, also in writing, his requirements or amendments.

Contents

1. Preliminaries
2. Responsibilities by the Contractor
3. Work Progress Report and Meetings
4. Workmanship
5. Electrical inspection and testing procedures

1. Preliminaries

A. Protection of the works

- (i) The Contractor shall provide, erect and maintain all necessary temporary casing, masking, fencing off and screening to partly finished work including work executed by sub-contractors (nominated or otherwise) and shall also provide all necessary temporary roofs, tarpaulins, screens, planking and general protection necessary to protect the works from damage by inclement weather, and provide all temporary gutters, pipes, surface water drains and the like for conveyance of rainwater and clear away when no longer required.

B. Drying the works

- (i) The Contractor shall be responsible for the adequate drying out of the works and for maintaining them at a suitable temperature and humidity until handed over.

C. Removing rubbish and cleaning

- (i) Remove all rubbish and debris from the site both as it accumulates from time to time and upon completion of the works and shall not bury or otherwise conceal the same upon the site. Clean the works internally and externally upon completion to the satisfaction of the Project Manager/Supervising Officers.

2. Responsibilities by the Contractor

- (i) Organization chart showing the names and ranks of the staff to be engaged in the project. The organization chart shall also show the telephone number of the staff to enable the Engineer or his representative to have efficient contact with any member of staff as mentioned in the organization chart during any stage of the project. The Engineer shall be informed immediately if there is any change in such chart.
- (ii) The work for opening and closing the trenches must be planned with the consideration of the other teams planning (Construction and Watsan).
- (iii) The program of work. The document shall show clearly the commencement and completion dates for different areas. The Contractor shall inform the MSF Energy Manager for approval if there are adjustments of the schedule during the course of the project.
- (iv) Sample board containing samples of all compact-sized materials to be used in the project for the MSF Energy Manager acceptance. All electrical equipment must be validated prior to installation.
- (v) The Contractor shall need to make his own arrangements of the tools and other utility services as deemed necessary for the works area and the execution of works.
- (vi) The Contractor shall provide the basic safety apparatus for their workers, e.g. safety glass, gloves, masks etc.
- (vii) The contractor must use suitable material to partition the working areas.
- (viii) A list of materials with detailed quantities and areas where these materials are installed, prior to the completion of the project.
- (ix) All materials to be used should be new and of the approved type, as specified in the Bill of Quantities.
- (x) Any modification from designed plan should be reported for approval before implementation. A new electrical layout indicating the changes should be submitted.

3. Work Progress Report and Meetings

- (i) The MSF Electricity Manager shall call project progress meetings in his office or at the site, as he deems necessary for the control of the Contract. Normally these meetings will be conducted daily. In the meeting, the Contractor is required to describe the progress of the project, scheduling for any anticipated delay or other relevant information against each activity. The Contractor shall arrange his approved site representative or other responsible person to attend such meetings.
- (ii) The Contractor shall send daily progress reports with pictures and work performed via email to the MSF Electricity Manager. A template of the daily progress report will be provided.
- (iii) Weekly meetings must be held to report the progress of work. The minutes of the meeting will be sent to the Contractor for acknowledgement and necessary action.


4. Workmanship

4.1 Panel Boards

- (i) Panel Boards must conform to existing standards for both MSF and Yemen, and other international standards (IEC, NEC, ICRC, NEMA, etc.). It will be the responsibility of the sub-contractors to provide the panel boards and install them. Panel Boards must not be installed without prior validation of the MSF Electricity Manager.
- (ii) All circuits should be identified or numbered. Printed copies of the position and electrical diagrams should be included inside the board, or in a sealed file close to the board. These diagrams must of course be up to date.

Technical Requirements:

- A minimum distance of 1 meter must be kept between a panel board and a window. Boards cannot be placed in front of doors or windows.
- Boards must be installed in dry places. When boards are installed outdoors, they must be at least IP65, the floor must be a dry slab or any other dry floor above the outdoor ground surface. They must be protected from the rain with appropriate roof and walls at least 2 meters around. If required the area around the shelter must be drained. The access to an electrical shelter must remain clear.
- The top third of an electrical board should ideally be placed at a height of between 150 and 200 cm.
- Example of Panel Board set up:











4.3 Cable installations

- (i) Junction boxes shall be installed for connecting cables and rubber grommets shall be used for all cable entries.
- (ii) Cable entries into a building shall be sealed by approved means to prevent the ingress of moisture.
- (iii) Each cable shall be clearly labeled in accordance with the drawings. All wiring terminations shall be finished in a neat and approved manner and shall each be separately identified by a wiring code number.
- (iv) When cables pass through walls, a piece of PVC sleeve of adequate size shall be inserted into the wall and the cables shall be drawn therein. Holes so created around the sleeves shall be fitted up with cement.
- (v) Rubber grommets shall be used to protect the cables passing through metal covers of panel boxes.
- (vi) Straight joints in cables should be avoided and Tee-joints in protective conductors with suitable connectors are acceptable.
- (vii) Power cabling shouldn't share with data/telephone cabling in the same trunking. It also follows the power cabling shouldn't run in parallel with data/telephone cabling.
- (viii) Power cables that carry high current shouldn't share trunking as this causes induction, in effect a reduced current carrying cable.
- (ix) Cable termination with breakers is accomplished with appropriate cable lugs.


4.4 Cable color standard

- (i) The following color code for electric cable must be followed:

	Single Phase	Three Phase
Phase Conductor (Line)	 Red or  Yellow or  Blue	 Line 1 Red  Line 2 Yellow  Line 3 Blue
Neutral Conductor	 Black	
Protective Conductor (Earth)	 Green-and-Yellow	

4.6 Cable connection in junction box

- (i) Cable connection inside the junction box must be made with “WAGO” clamps (see picture) not with tape.



4.7 Lighting

- (i) Fixed lightings: All ungrounded lighting fixtures should be class II equipment – in particular all external parts of bulb holders should be made from nonconductive material.
- (ii) **Interior lighting** fixtures must be at least **IP 41** (no possibility of ingress of solid objects over 1mm). **External lighting** and lighting fixtures must be at least **IP65**.
- (iii) Lights should be **LED lighting technology**.
- (iv) The LED lights should have white lighting more than (4000K).
- (v) The wall light switches must be installed at 120cm high from the ground.
- (vi) Photo sensor
 - a. Light sensor with possible settings from 2 to 2000 lux with fixed delay (60s) adapted to the load (regarding the number and type of lights).
 - b. If possible, avoid extra relay.
 - c. To be installed, if possible, directed to North; far from light sources.
 - d. Example: Schneider Electric IC2000

4.8 Sockets and Switches

- (i) All plugs and socket outlets must comply with IEC Standards (IEC 60884-1).
- (ii) Ingress protection rate: Sockets must include ‘children protection’ measures that avoid the introduction of any metallic object inside of the socket when no plug is inserted. At least IP 4x is requested.
- (iii) The OT sockets must be waterproof IP65 and protected by a differential circuit breaker 30mA. The sockets must be installed at 120cm high from the ground.
- (iv) Sockets above the room tables must be at 85cm high from the ground.
- (v) Switches for household and similar fixed electrical installations must comply with IEC Standards (IEC 60669-1).

4.9 Back-up system

- (i) The OT department and the C-ARM device has UPS. All the rest of the installation must be provided and installed by the contractor as in the electrical design.
- (ii) The back-up circuit is a separated circuit. It is indicated with a different color in the electrical drawings.
- (iii) The back-up equipment must be tagged with “back-up”.
- (iv) The UPS grounding cable must be connected to the equipotential grounding.

5. ELECTRICAL INSPECTION AND TESTING PROCEDURES

During the development of works, three types of inspection shall be conducted:

- (1) **Equipment validation inspection:** Prior to installation, equipment shall be sent for inspection of Electricity Manager. The following will be checked:
 - Visual inspection;
 - Quality check: is the equipment of right brand/quality;
 - Rating check: is the equipment the correct rating and according to technical specifications and drawings (nameplate wattage, voltage and current ratings and types, area classification and environment, circuit breaker ratings sizes, etc);
- (2) **Equipment installation inspection:** After equipment is installed, it will be checked for compliance with MSF technical specifications, technical drawings, single line diagram and safety guidelines. No testing shall be performed before installation inspection has been conducted and validated.
- (3) **Completion of works inspection:** At the completion of the work, the Engineer or his representative will check the installation performed by the Contractor using the following check list. The Contractor shall rectify all the outstanding items discovered before the final acceptance

5.1. Panels, circuit breakers and main switches

- (i) No visible damage to impair safety.
- (ii) Every circuit breaker, main switch and RCCB is provided with legible **labels** giving their ratings.
- (iii) Every panel, circuit breaker and main switch is provided with a legible and durable identification **label**.
- (iv) All accessible live parts are screened with insulating plate or earthed metal.
- (v) All exposed conductive parts are effectively earthed.
- (vi) Cables at the panel are terminated with adequate cable lugs.
- (vii) Circuits connected to circuit breakers are in accordance with the schematic diagram.
- (viii) Exposed cables are protected by suitable means.
- (ix) All surface trunking and conduits are properly supported.

5.2. Main power cables

- (i) No visible damage to impair safety
- (ii) Cables protected against mechanical damage
- (iii) Correct phase identification provided at both ends of the cable.
- (iv) Cables and ducting are adequately supported.

5.3. Earth

- (i) Equipotential bonding conductors effectively connected to metal pipes, e.g. water pipes and gas pipes, as well as metallic parts of structural framework.
- (ii) Grounding system is connected with appropriate earthing conductor and connectors.

5.4. Switches and Sockets

- (i) Socket outlets for patient bed shall be installed 1.20m from the floor, the normal sockets at 60 cm and for the corridor at 80 cm from the floor
- (ii) Ground wire must be properly connected to the socket earth pin
- (iii) No socket outlet is installed closed to water tap, gas tap or cooker.
- (iv) Switch and Socket outlets in bathrooms and toilets should be waterproof.
- (v) Sockets shall be mechanically held in position during the insertion and the removal of the power plugs.
- (vi) Cover of the sockets shall be tightly attached to the body and there shall be no gap for the ingress of water and moisture.

5.5 Tests

- (i) A continuity test shall be performed for each circuit as such there are no circuits which are open in any end.
- (ii) A megger test or insulation test has to be performed to detect any fault across the circuit line which may cause tripping, short circuit and grounding.
- (iii) A clamp meter test shall be performed to verify a balanced load system for three-phase connection.
- (iv) A thermal reading shall be performed on the panel board should there be excessive heat dissipated.

6. Equipment quality, brands and equivalent – Examples [PHILIPS / OPPEL]

LIGHT, LED PANEL 30x30 cm, 24W, Surface mount (PHILIPS)

PHILIPS



EMERGENCY LIGHT, LED 8 W waterproof IP65 with Battery Autonomy 1-3h



END OF DOCUMENT