



BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN
WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ,YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Detials	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
	1: The contractor must visit the site and fully assess conditions before submitting prices. 2: No work item will be accepted unless it is fully completed, commissioned, tested, and operational. 3: No work shall commence or be accepted without prior approval of samples by the AFH Engineer, also strict adherence to all instructions issued by the supervising engineer is mandatory. 4: The contractor must comply with all occupational security and safety requirements for workers at all times. 5: All waste, and obstructions shall be removed from the site and disposed of in approved locations. 6: All obstructions and debris must be removed and moved from work sites to a suitable location, and work sites must be handed over clean, organized, and free from any waste or obstacles, in accordance with the engineer's instructions. 7: All materials must be of high quality and from approved reputable brands. 8: The contractor shall carry out all required tests in accordance with the technical specifications and standards. 9: A detailed work implementation plan must be submitted and approved by the engineer prior to commencing any activity. 10: All works must be executed in full compliance with approved drawings, technical specifications, engineering standards, and the instructions of the supervising engineer or their representative. 11: The contractor shall conduct a detailed on-site verification of the well prior to commencement of any works. This shall include, but not be limited to, assessment of static and dynamic water levels, well productivity, and water quality. The contractor is fully responsible for confirming that the well conditions are adequate and compatible with the project design and requirements. Any discrepancies or concerns must be reported to the supervising engineer for review and approval before proceeding with implementation.							1. يجب على المقول زيارة الموقع وتقييم الظروف تقييمًا شاملاً قبل تقديم عروض الأسعار. 2. لن يُقبل أي عمل ما لم يكن مكتملاً تمامًا، ومُشغلاً، ومُختبرًا، وجاهزًا للتشغيل. 3. لا يجوز البدء بأي عمل أو قبوله دون موافقة مسبقة من مهندس شركة AFH على العينات، كما أن الالتزام التام بجميع التعليمات الصادرة عن المهندس المشرف إلزامي. 4. يجب على المقول الالتزام بجميع متطلبات السلامة والأمن المهني للعمل في جميع الأوقات. 5. يجب إزالة جميع النفايات والعوائق من الموقع والتخلص منها في الأماكن المخصصة. 6. يجب إزالة جميع العوائق والحطام ونقلها من مواقع العمل إلى مكان مناسب، ويجب تسليم مواقع العمل نظيفة ومنظمة وخالية من أي نفايات أو عوائق، وفقًا لتعليمات المهندس. 7. يجب أن تكون جميع المواد عالية الجودة ومن علامات تجارية معتمدة وذات سمعة طيبة. 8. يجب على المقول إجراء جميع الاختبارات المطلوبة وفقًا للمواصفات والمعايير الفنية. 9. يجب تقديم خطة تنفيذ عمل مفصلة واعتمادها من قبل المهندس قبل البدء بأي نشاط. 10- يجب تنفيذ جميع الأعمال بما يتوافق تمامًا مع الرسومات المعتمدة والمواصفات الفنية والمعايير الهندسية وتعليمات المهندس المشرف أو من ينوب عنه. 11- يجب على المقول إجراء فحص ميداني مفصل للبرار قبل البدء بأي أعمال. ويشمل ذلك، على سبيل المثال لا الحصر، تقييم مستويات المياه الساكنة والديناميكية، وإنتاجية البرار، وجودة المياه. يتحمل المقول المسؤولية الكاملة عن التأكد من أن ظروف البرار مناسبة ومتوافقة مع تصميم المشروع ومتطلباته. يجب إبلاغ المهندس المشرف بأي اختلافات أو مخاوف للمراجعة والموافقة قبل المعنى قمتما في التنفيذ. المواصفات باللغة الإنجليزية هي المرجع الاساسي للمشروع



BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN
WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ,YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
1	Solar Submersible Water Pump System Supply, install, test, and commission a complete solar-powered submersible pumping system, of high-quality European origin, designed to operate efficiently under high ambient temperatures (up to 50°C). All system components shall be corrosion-resistant and suitable for harsh environmental conditions. The scope includes all materials, equipment, transportation, installation, testing, commissioning, and operator training, in accordance with the following technical specifications: Technical Specifications Hydraulic Performance The system shall be designed for a total dynamic head (TDH) of not less than 100 m. The pump discharge capacity shall be not less than 2 liters/second. Pump & Motor The submersible pump shall be coupled with a motor whose power rating is not less than 1.3 times the required pump power. The pump shall be equipped with a strainer to prevent the entry of sand and impurities. Inverter / Controller The inverter capacity shall be at least 1.5 times the motor power. The inverter shall support hybrid operation (solar and grid/diesel if applicable). The scope includes supply and installation of: Combiner box with appropriate circuit breakers and protections. Weatherproof enclosure for the inverter. Solar PV Array The total PV capacity shall be not less than 1.7 times the motor power, using high-efficiency solar panels. Mono-crystalline N-Type TOPCon, Minimum efficiency 23%. Panels shall be installed near the well at a location agreed upon with the community and engineer. The item includes construction of reinforced concrete foundations (mix ratio 1:2:4) for the Hot Dip Galvanized steel mounting structure 50 * 50 * 80 cm with the necessary excavation for the concrete foundations to a depth of no less than 50 cm, and insulation of the buried parts and painting and finishing to all concrete works according to the engineer's instructions. Electrical Cabling (DC Side) Cables connecting solar panel arrays to the combiner box shall be minimum 10 mm². Cables between combiner box and inverter shall be minimum 10 mm² The wires connecting the junction box and the inverter must be DC wires, size 50 mm. Pumping Line Supply and install HPDE rising main, diameter 2 inches, PN16, up to a depth of 33 m inside the well. Protection & Control System Supply and install an automatic dry-run protection sensor to stop pump operation when water level drops below safe limits. Solar panels shall be installed at a minimum distance of 10 m from the well. Valves Supply and install Ductile Iron (DI) double-flanged non-return valve, Ø50 mm, compliant with British Standards. Earthing & Lightning Protection Provide a complete earthing system to protect against lightning strikes, including: Copper conductor not less than 10 mm². Copper earth electrode installed in properly treated soil (salt and charcoal). All required accessories for a fully functional grounding system. Pump Power Cable Installation Supply all necessary pump cables (minimum 3×6 mm²) and protect them using plastic conduits (minimum Ø1.5 inch). Cables shall be waterproof and properly routed inside and outside the well, with external sections buried at a minimum depth of 50 cm. Mechanical Installation The pump shall be securely installed using durable suspension system (double-secured stainless steel/nylon rope or approved equivalent). Testing & Commissioning The system shall be tested and operated continuously for a minimum of 48 hours. Final acceptance shall be subject to satisfactory performance, compliance with specifications, and approval by the Engineer. Training The contractor shall provide on-site operation and maintenance training to designated beneficiaries or operators.	L.S	1					نظام مضخة مياه غاطسية تعمل بالطاقة الشمسية توريد وتركيب واختبار وتشغيل نظام مضخ غاطس يعمل بالطاقة الشمسية، عالي الجودة، من أصل أوروبي، مصمم للعمل بكفاءة في درجات حرارة محيطية عالية (تصل إلى 50 درجة مئوية). يجب أن تكون جميع مكونات النظام مقاومة للتآكل ومناسبة للظروف البيئية القاسية. يشمل نطاق العمل جميع المواد والمعدات والنقل وتركيب واختبار والتشغيل وتدريب المشغلين، وفقاً للمواصفات الفنية التالية: المواصفات الفنية الأداء الهيدروليكي يجب تصميم النظام لارتفاع ديناميكي إجمالي (TDH) لا يقل عن 50 متراً. يجب ألا تقل سعة تصريف المضخة عن 2 لتر/ثانية. كفاءة والمحرك يجب توصيل المضخة الغاطسية بمحرك لا تقل قوته عن 1.3 ضعف قدرة المضخة المطلوبة. يجب أن تكون المضخة مزودة بمصفاة لمنع دخول الرمل والشوائب. المعكس/بوحة التحكم يجب أن تكون سعة المعكس 1.5 ضعف قدرة المحرك على الأقل. يجب أن يدعم المعكس التشغيل الهجين (الطاقة الشمسية والشبكة/البترول). (إن وجد). يشمل نطاق العمل توريد وتركيب ما يلي: مستودق تجميع مزود بفراموطر دوائر كهربائية وأجهزة حماية مناسبة. مستودق مقاومة للعوامل الجوية للمعكس. مصفوفة الألواح الشمسية الكهروضوئية يجب ألا تقل السعة الإجمالية للألواح الشمسية الكهروضوئية عن 1.7 ضعف قدرة المحرك، باستخدام ألواح شمسية عالية الكفاءة أحادي البلورة من النوع N، كفاءة دنيا 23%. يجب تركيب الألواح بالقرب من البئر في موقع يتم الاتفاق عليه مع المجتمع المحلي والمهندسين. يشمل هذا البند إنشاء أبعاد خرسانية مسطحة (نسبة خلط 1:2:4) بمقاس 80 * 50 * 80 سم لتهيئة التثبيت الفولاذي مع الحفر اللازم للقواعد الخرسانية بحقق لا يقل عن 50 سم والموال. الأجزاء المدفونة مع التغطى والتفتيش الجيد لجميع الأبعاد الخرسانية وفق توجيهات المهندسين. التمهيدات الكهربائية (جانب التيار المستمر) يجب ألا يقل مقطع الكابلات التي تربط مصفوفات الألواح الشمسية بمستودق التجميع عن 10 مم². يجب ألا يقل مقطع الكابلات بين مستودق التجميع والمعكس عن 10 مم². يجب أن تكون الأسلاك التي تربط بين مستودق التجميع والآنفرتر من أسلاك التيار المستمر مقاس 50 مم. خط الضخ توريد وتركيب أنبوب رئيسي للرفع مصنوع من الدوالي إيثيلين عالي الكثافة، بقطر 2 بوصة، وضغط اسمي 16، حتى عمق 33 متراً داخل البئر. الحماية نظام التحكم توريد وتركيب جساس حماية تلقائي من التشغيل الجاف لإيقاف تشغيل المضخة عند انخفاض مستوى الماء عن الحدود الآمنة. يجب تركيب الألواح الشمسية على مسافة لا تقل عن 10 أمتار من البئر. الصمامات توريد وتركيب صمام عدم رجوع مزدوج الحواف من الحديد المطاوع، بقطر 50 مم، متوافق مع المعايير البريطانية. التأريض والحماية من الصواعق توفير نظام تأريض كامل للحماية من الصواعق، يشمل: موصل نحاسي لا يقل عن 10 مم². قطب تأريض نحاسي مثبت في تربة معالجة بشكل صحيح (ملح وفحم). جميع الملحقات اللازمة لإنشاء تأريض فعال. تركيب كابلات طاقة المضخة توريد جميع كابلات المضخة اللازمة (3×6 مم² كحد أدنى) وحمايتها باستخدام أنابيب بلاستيكية (قطر 1.5 بوصة كحد أدنى). يجب تروجه الكابلات بشكل صحيح داخل وخارج البئر، مع دفن الأجزاء الخارجية على عمق لا يقل عن 50 سم. التركيب الميكانيكي يجب أن تكون المضخة مثبتة بحكام باستخدام نظام تعليق متين (حل مزدوج التثبيت من الفولاذ المقوّم للصدأ/الباليون أو ما يعقله من الأنظمة المعتمدة). الاختبار والتشغيل يجب اختبار النظام وتشغيله بشكل متواصل لمدة لا تقل عن 48 ساعة. يخضع القبول النهائي للآداء العرضي، والامتثال للمواصفات، وموافقة المهندس. التدريب يقدّم المقاول تدريباً ميدانياً على التشغيل والصيانة للمستفيدين أو المشغلين المعيّنين.



BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN
WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ,YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
2	Protection Fence for Solar Panels							توريد وتركيب سياج حماية لالواح الطاقة الشمسية
2.1	Supply and install a complete protective fencing system for the solar panels and all associated accessories. The fence shall be designed to ensure security, durability, and resistance to environmental conditions, in accordance with the following specifications and as directed by the supervising Engineer: Technical Specifications Fence Mesh (Chain-Link) The fence shall be constructed using plastic-coated galvanized chain-link mesh. Maximum mesh opening size shall not exceed 70 mm (7 cm). The total fence length shall be sufficient to fully enclose the solar panel area, as per site conditions and Engineer's instructions. The fence height shall be 2.0 m above ground level. Fence Posts (Columns) Posts shall be made of galvanized iron pipes, diameter 2 inches, total length 2.5 m. Installation shall include: 0.5 m embedded in concrete foundation. 2.0 m above ground level. Spacing between posts shall be 2.0 m maximum. Posts shall be coated with: Three layers of anti-rust (primer) paint. Two finishing coats in a color approved by the WASH Engineer. Concrete Works Post foundations shall be constructed using plain concrete (1:2:4 mix ratio). A continuous concrete curb/strip footing shall be provided beneath the mesh with minimum dimensions of 20 × 20 cm to secure and protect the fence. Additional concrete blocks (40 × 40 × 50 cm) shall be used where required to strengthen the structure, as directed by the Engineer. Reinforcement & Fixing Provide steel reinforcement bars (Ø8 mm) horizontally between posts at both the top and bottom of the mesh to ensure proper fixation and rigidity. All connections shall be securely tied and fixed to prevent sagging or displacement. Access Gate Provide and install one lockable access gate with dimensions 1.0 m (width) × 2.0 m (height). The gate shall be constructed from the same mesh material and supported by: Galvanized iron frame (1.5-inch diameter, 3 mm thickness). Gate posts made of 3-inch diameter galvanized iron pipes. The gate shall be equipped with: Heavy-duty hinges. Secure locking system. Proper alignment and smooth operation. Painted in the chosen color according to the engineer's instructions, with the donor's logo placed on the door. Site Preparation & Finishing The contractor shall carry out site leveling within the fenced area. Provide and compact a gravel (sub-base) layer of not less than 6 cm thickness over the entire enclosed area.	L.S	1					توريد وتركيب سياج حماية لالواح الطاقة الشمسية توريد وتركيب نظام سياج حماية متكامل للالواح الشمسية وجميع ملحقاتها. يجب تصميم السياج لضمان الأمن والمثانة ومقاومة الظروف البيئية، وفقاً للوصفات التالية ويوجيه من المهندس المشرف: الوصفات الفنية شبكة السياج (الشبك المتسلي) يتمتع السياج من شبك متسلي مجلفن مغلف بالبلاستيك. يجب ألا تتجاوز حجم فتحة الشبكة 70 سم (7 سم). يجب أن يكون طول السياج الإجمالي كافياً لتطويق منطقة الألواح الشمسية بالكامل، وفقاً لظروف الموقع وتعليمات المهندس. يجب أن يكون ارتفاع السياج 2.0 متر فوق مستوى سطح الأرض. أعمدة السياج تُصنع الأعمدة من أنابيب حديدية مجلفنة، قطرها 2 بوصة، وطولها الإجمالي 2.5 متر. يشمل التركيب ما يلي: فوس 0.5 متر في أساس خرساني. ارتفاع 2.0 متر فوق مستوى سطح الأرض. يجب ألا تتجاوز المسافة بين الأعمدة 2.0 متر. تُطلى الأعمدة بما يلي: ثلاث طبقات من الطلاء المقوم للصدأ (الطبقة التمهيدية). طبقتان نهائيتان بلون معتمد من مهندس المياه والصرف الصحي. الأسفلت الخرسانية تُصنع أساسات الأعمدة من الخرسانة العادية (نسبة خلط 1:2:4). يجب توفير قاعدة خرسانية ممتدة أسفل الشبكة بأبعاد لا تقل عن 20 × 20 سم لتثبيت السياج وحمايته. يجب استخدام كتل خرسانية إضافية (40 × 40 × 50 سم) عند الحاجة لتقوية الهيكل، وفقاً لتوجيهات المهندس. التسليح والتثبيت يجب توفير قضبان تسليح فولاذية (قطر 8 سم) أفقياً بين الأعمدة في أعلى وأسفل الشبكة لضمان التثبيت والصلابة المتساويين. يجب ربط جميع الوصلات وتثبيتها بإحكام لمنع التزلزل أو الإزاحة. بوابة الدخول يجب توفير وتركيب بوابة دخول واحدة قابلة للتفلل بأبعاد 1.0 متر (عرض) × 2.0 متر (ارتفاع). يجب أن تُصنع البوابة من نفس مادة الشبكة وأن تكون مدعومة بما يلي: إطار من الحديد المجلفن (قطر 1.5 بوصة، سمك 3 مم). أعمدة البوابة مصنوعة من أنابيب حديد مجلفن بقطر 3 بوصات. يجب أن تكون البوابة مزودة بما يلي: مفصلات شديدة التحمل. نظام قفل آمن. محددات دقيقة وتشغيل سلس. تمهال بالون المختار بحسب توجيهات المهندس مع عمل شعار المانح على الباب. تجهيز الموقع والتشطيب تؤدى المتاول تسوية الموقع داخل المنطقة المسوّرة. توفر طبقة من الحصى (طبقة أساسية) لا يقل سمكها عن 6 سم، وضغطها على كامل المنطقة المسوّرة. يجب أن تكون جميع ألوان الطلاء وتفصيل التشطيب معتمدة من مهندس المنظمة.



BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN
WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ,YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
3	Civil Works							الأعمال المدنية
3.1	Carry out site clearance, excavation, and leveling works within the designated project area, as directed by the AFH Engineer. The scope shall include removal of all obstacles, debris, vegetation, and unsuitable materials, and their proper disposal at approved locations in accordance with project requirements and the Engineer's instructions.	L.S	1					تنفيذ أعمال إزالة العوائق والخفر والتسوية في الموقع المحدد للمشروع، وفقاً لتوجيهات مهندس المنظمة. يشمل نطاق العمل إزالة جميع العوائق والحطام والنباتات والمواد غير المناسبة، والتخلص منها بشكل سليم في المواقع المعتمدة وفقاً لمتطلبات المشروع وتعليمات المهندس.
3.2	Construct a circular inspection chamber (protection wall) around the well, with an external diameter of 3.0 m and a height of 2.5m, including all civil, structural, and finishing works, in accordance with the following specifications and as directed by the supervising Engineer: Excavation & Backfilling Carry out excavation to the required dimensions and levels. Backfilling shall be done using suitable approved material, properly compacted in layers. Sub-Base (Soling Layer) Provide and lay a 20 cm thick layer of soling stones, well compacted and leveled. Plain Concrete Floor Construct a plain concrete slab (1:2:4 mix ratio) with a minimum thickness of 10 cm. Provide a PVC drainage pipe (Ø2 inches) embedded within the slab to allow proper drainage of water. Wall Construction Construct the circular wall using solid concrete blocks laid in cement mortar (1:3). All cement used shall be sulphate-resistant cement (SRC), suitable for aggressive soil conditions. Plastering (Internal & External) Apply internal and external plastering with cement mortar (1:3), thickness 2 cm, including proper finishing and edge alignment. External plaster shall be finished using weather-resistant coating (Helicon or equivalent). Provide cement splatter (roughcast) to external surfaces using sulphate-resistant cement for improved durability. Access Cover Supply and install a steel cover (minimum 3 mm thickness) complete with a steel frame (4 cm × 4 cm). The cover shall be: Properly fitted and secured. Painted with two coats of anti-rust primer and two finishing coats in a color approved by the Engineer. Chamber Door: Supply and install a steel door (minimum 3 mm thickness) complete with a steel frame (4 cm × 4 cm). 2m H, 0.9 m w Properly fitted and secured. Painted with two coats of anti-rust primer and two finishing coats in a color approved by the Engineer. Painting Works Apply two coats of water-based primer followed by two coats of approved paint to all exposed surfaces. Final color shall be as determined by the supervising Engineer. The contractor shall paint the organization's logo on the structure as per provided design. Rehabilitation of Existing Well Head Plaster and level the external surfaces of the existing well head using sulphate-resistant cement mortar. Carry out any additional required works to ensure proper integration with the new structure, as directed by the Engineer.	L.S	1					إنشاء غرفة تفتيش دائرية (جدار حماية) حول البئر، بقطر خارجي 3.0 متر وارتفاع 2.5 متر، شاملة جميع الأعمال المدنية والإنشائية والتشطيبية، وفقاً للوصصفات التالية وبترجيح من المهندس المشرف: الخفر والردم قم بالخفر إلى الأبعاد والمستويات المطلوبة. يجب أن يتم الردم باستخدام مواد معتمدة مناسبة، مع دكها جيداً على طبقات. الطبقة الأساسية (طبقة الأساس) قم بتوفير ووضع طبقة من الحجار الأساس بسمك 20 سم، مع دكها وتسويتها جيداً. الأرضية الخرسانية العادية قم بإنشاء بلاطة خرسانية عادية (بنسبة خلط 1:2:4) بسمك لا تقل عن 10 سم. قم بتوفير أنبوب تصريف من مادة PVC (قطر 2 بوصة) مثبت داخل البلاطة للسماح بتصريف المياه بشكل صحيح. بناء الجدار قم ببناء الجدار الدائري باستخدام كتل خرسانية صلبة موضوعة في مونة أسمنتية (1:3). يجب أن يكون جميع الأسمنت المستخدم من النوع المقوم للكثريات (SRC)، وهو مناسب للتربة العدوانية. الشروط. التجصيص (الداخلي والخارجي) ينطبق التجصيص الداخلي والخارجي باستخدام مونة أسمنتية (1:3)، بسمك 2 سم، مع مراعاة التشطيب المناسب ومحاذاة الحواف. ينتهي التجصيص الخارجي باستخدام طلاء مغوم للعوامل الجوية (هيليكون أو ما يعادلها). ينطبق طلاء خشن (طلاء خشن) على الأسطح الخارجية باستخدام أسمنت مغوم للكثريات لزيادة المتانة. طلاء الوصول توريد وتركيب غطاء فولاذي (بسمك 3 مم كحد أدنى) مزود ببطار فولاذي (4 سم × 4 سم). يجب أن يكون الغطاء: مثبتاً بإحكام. مطابقاً لمطابقين من الطلاء التمهيدي المقوم للمصدأ ومطابقين من الطلاء النهائي بلون معتمد من قبل المهندس. باب العرفة توريد وتركيب باب فولاذي (بسمك 3 مم كحد أدنى) مزود ببطار فولاذي (4 سم × 4 سم). ارتفاع 2م وعرض 0.9 م مثبتاً بإحكام. مطابقاً لمطابقين من الطلاء التمهيدي المقوم للمصدأ ومطابقين من الطلاء النهائي بلون معتمد من قبل المهندس. أعمال الطلاء ينطبق مطبقين من الطلاء التمهيدي المائي، متوفاً بمطابقين من الطلاء المعتمد على جميع الأسطح المكشوفة. يحدد اللون النهائي من قبل المهندس المشرف. يقوم المقاول بطلاء شعار المنظمة على الهيكل وفقاً للتصميم المقدم. إعادة تأهيل رأس البئر القائم التجصيص والتسوية لسطح الأسطح الخارجية لرأس البئر الحالي بمونة أسمنتية مقومة للكثريات. يُنجز أي أعمال إضافية مطلوبة لضمان التكامل الدائم مع الهيكل الجديد، وفقاً لتوجيهات المهندس.

BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ,YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
3.3	Inspection chambers with an external size of 1 m * 1 m and a height of 1 m, including the following: - Digging and backfilling according to the required dimensions. - Spreading a layer of 20 cm thick sullen stones. - Making a clean concrete for the floor with a thickness of 10 cm and a mixing ratio of (1:2:4) using sulphate-resistant cement with making a plastic pipe with a diameter of 2 inches to drain the water. - Building solid blocks with cement mortar (1:3) using sulphate-resistant cement. - Internal and external cladding with the edges with a thickness of 2 cm with cement mortar (1:3) for external cladding, use Helsen with water spraying three times a day for a period of not less than a week. - Cement splashing for the external walls using sulphate-resistant cement. - Supplying and installing a 3 mm thick iron cover with an iron frame made of 4 cm * 4 cm shalman with hinges, locks and painting With two layers of anti-rust paint and two layers of a suitable color determined by the supervising engineer. - Painting the inspection room with two layers of water-based primer and two layers of a suitable color determined by the supervising engineer, and placing the logo of the organization and the donor on the inspection room.	NO	1					أعمال إنشاء غرف تفقيش بأبعاد خارجية 1 متر * 1 متر وارتفاع 1 متر، وتشمل ما يلي: - الحفر والردم وفقاً للأبعاد المطلوبة. - فرد طبقة من الحصى الخشن بسمكة 20 سم. - صب خرسانة نظيفة للأرضية بسمكة 10 سم بنسبة خلط 1:2:4 باستخدام أسمنت مقاوم للكبريتات، مع تركيب الأبواب بلاستيكي بغتر 5 سم لتصريف المياه. - بناء كتل خرسانية صلبة باستخدام مونة أسمنتية بنسبة 1:3 باستخدام أسمنت مقاوم للكبريتات. - تركيب كبوة داخلية وخارجية بحواف بسمكة 2 سم باستخدام مونة أسمنتية بنسبة 1:3، بالنسبة للكبوة الخارجية، يُسمح باستخدام مادة مائعة للتسرب مع رش الماء ثلاث مرات يومياً لمدة لا تقل عن أسبوع. - ريش الجدران الخارجية بالأسمنت المقاوم للكبريتات. - توريد وتركيب غطاء حديدي بسمكة 3 مم بإطار حديدي مصنوع من خشب شالمان مقاس 4 سم * 4 سم، مزود بمفصلات وأقفال، ومغطى بطبقتين من الطلاء المقاوم للصدأ وطبقتين من لون مناسب يحدده المهندس المشرف. - طلاء غرفة التفقيش بطبقتين من الطلاء التمهيدي المائي وطبقتين من لون مناسب يحدده المهندس المشرف، ووضع شعار المنظمة والجهة المالحة على غرفة التفقيش.
3.4	Construction of Concrete Curb and Interlocking Pavement Around Well Area Supply all materials, labor, equipment, and supervision required to construct concrete curb (edge beam) and interlocking pavement around the well area, in accordance with approved specifications and as directed by the supervising Engineer. Construct a continuous concrete curb of suitable dimensions and height around the well area, as approved by the Engineer. Concrete compressive strength shall be not less than 300 kg/cm². Cement mortar for finishing shall be (1:3 mix ratio). Excavation shall be carried out to the required depth and alignment. Provide a stone soling/base layer properly bedded in plain concrete (1:2:4 mix ratio) to serve as a foundation for the curb. All concrete works shall preferably use sulphate-resistant cement (SRC). Proper curing shall be ensured by watering at least twice daily for a minimum period of 7 days. The curb shall be finished and painted on three sides with approved paint color as directed by the Engineer. Supply and install colored interlocking concrete paving blocks (preferably honeycomb type or approved equivalent). Minimum compressive strength of paving blocks shall be 300 kg/cm². The works shall include: Site leveling, excavation, and preparation. Backfilling and compaction of subgrade to required levels. Preparation of suitable bedding layer (as directed by the Engineer). Paving blocks shall be properly aligned, compacted, and finished to provide a uniform and stable surface. After installation, the pavement shall be cured by water spraying twice daily for at least 7 days, as instructed by the Engineer.	m²	24					توفير جميع المواد والعمالة والمعدات والإشراف اللازم لإنشاء رصيف خرساني (غاية) ورصيف متشابك حول منطقة البئر، وفقاً للمواصفات المعتمدة وبترجيحه من المهندس المشرف. إنشاء رصيف خرساني متصل بأبعاد وارتفاع مناسبين حول منطقة البئر، وفقاً لما يوافق عليه المهندس. يجب ألا تقل مقاومة الخرسانة للضغط عن 300 كجم/سم². يجب أن تكون نسبة خلط مونة الأسمنت للتشطيب 1:3. يجب تنفيذ أعمال الحفر إلى العمق والمحاذاة المطلوبة. توفير طبقة أساسية/حجرية مثقبة بشكل صحيح في خرسانة عالية (نسبة خلط 1:2:4) لتكون بمثابة أساس للرصيف. تُفضل استخدام أسمنت مقاوم للكبريتات في جميع أعمال الخرسانة. يجب ضمان المعالجة المناسبة عن طريق الري مرتين يومياً على الأقل لمدة لا تقل عن 7 أيام. يجب تشطيب الرصيف وملائته من ثلاثة جوانب بلون طلاء معتمد وفقاً لتوجيهات المهندس. اليدب يشمل توريد وتركيب بلاطات رصيف خرسانية متشابكة ملونة (تفضل (من النوع ذي البنية الخلوية أو ما يعقله المعتمد). يجب ألا تقل مقاومة الضغط لبلاط الرصيف عن 300 كجم/سم². تشمل الأعمال ما يلي: تسوية الموقع، والحفر، والتحضير. ردم وضغط الطبقة التحتية إلى المستويات المطلوبة. تحضير طبقة التأسيس المناسبة (وفقاً لتوجيهات المهندس). يجب محاذاة بلاط الرصيف وضغطه وتشطيبه بشكل صحيح بسلح توفير سطح موحد ومستقر. بعد التركيب، يُعالج الرصيف برش الماء مرتين يومياً لمدة لا تقل عن 7 أيام، وفقاً لتعليمات المهندس.
4	Water Point and Water Tank							نقطة مياه وخزان مياه



BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN
WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ,YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
4.1	Supply and Installation of 5,000-Liter Polyethylene Water Tank Supply and install a high-quality, high-pressure polyethylene water tank Minimum Warranty 10 Years, with a capacity of 5,000 liters, complete with all necessary fittings and accessories. This includes float valves, triple-layer, control valves, and all required special connection components. The scope of work shall include: Installation of an inlet (rising) pipeline using PVC pipes, PN 10, with a diameter of 1.5 inches. Installation of an outlet (distribution) pipeline using PVC pipes, PN 10, with a diameter of 1.5 inches. Provision and installation of auxiliary piping using PVC pipes, PN 10, with a diameter of 0.75 inches. Supply and installation of high-quality Italian-type brass gate valves, 1.5 inches in diameter, installed on both inlet and outlet sides of the tank. Installation of 8 plastic taps of 0.75-inch diameter, arranged evenly (4 taps on each side), of durable and approved quality, the item include: Installation of overflow piping (3-inch diameter) to safely discharge excess water. Supply and installation of a rainwater drainage system using 2-inch diameter PVC pipes, ensuring proper slope and connection to surface drainage. Preparation of the tank base by finishing the platform with cement mortar (mix ratio 1:3), ensuring a smooth, level, and stable surface. Provision and installation of galvanized steel tie wires (or equivalent fixing system) to securely anchor the tank from bottom to top in both directions, including painting with anti-corrosion coating (white color) to protect against environmental and erosion factors. All works shall be executed in accordance with the instructions and approval of the supervising engineer. The contractor shall also ensure the placement of the organization's and donor's logos on the tank as per the directives of the Engineering Officer. The item price shall include all materials, labor, tools, transportation, and any other requirements necessary for the complete and proper execution of the works.	No	1					توريد وتركيب خزان مياه من البولي إيثيلين سعة 5000 لتر توريد وتركيب خزان مياه عالي الجودة وعالي الضغط من البولي إيثيلين بسعة 5000 لتر ضمان 10 سنوات، مزود بجميع التجهيزات والملحقات اللازمة. يشمل ذلك مصابيات عالمة، ومصمامات تحكم ثلاثية الطبقات، وجميع مكونات التوصيل الخاصة المطلوبة. يشمل نطاق العمل ما يلي: تركيب خط أنابيب مدخل (مصاعد) باستخدام الأنابيب PVC، ضغط اسمي 10، بقطر 1.5 بوصة. تركيب خط أنابيب مخرج (توزيع) باستخدام الأنابيب PVC، ضغط اسمي 10، بقطر 1.5 بوصة. توفير وتركيب أنابيب مساعدة باستخدام الأنابيب PVC، ضغط اسمي 10، بقطر 0.75 بوصة. تركيب مصمامات بوابة أحادية الطبقة عالية الجودة بقطر 1.5 بوصة، مثبته على جانبي مدخل ومخرج الخزان. تركيب ٨ صناديق بلاستيكية بقطر ٠.٧٥ بوصة، موزعة بالتساوي (٤ صناديق على كل جانب)، من نوعية مثبته ومعتمدة. بولي إيثيلين بقطر ٠.٧٥ بوصة، موزعة بالتساوي (٤ صناديق على كل جانب)، من نوعية مثبته ومعتمدة. تركيب أنابيب تصريف فائض المياه (بقطر ٣ بوصات) لتصريف المياه الزائدة بأمان. توريد وتركيب نظام تصريف مياه الأمطار باستخدام الأنابيب PVC بقطر ٢ بوصة، مع ضمان العمل المناسب والتوصيل بشبكة الصرف الصحي. تجهيز قاعدة الخزان بتسوية المصفاة بمونة اسمي (نسبة خلط ١:٣)، مع ضمان سطح أملس ومستوي وثابت. توفير وتركيب أسلاك ربط فولاذية مجلفنة (أو نظام تثبيت مكافئ) لتثبيت الخزان بإحكام من الأسفل إلى الأعلى في كلا الاتجاهين، بما في ذلك طلائه بطبقة مقاومة للتآكل (لون أبيض) لحماية من العوامل البيئية وعوامل التعرية. يجب تنفيذ جميع الأعمال وفقاً للتعليمات وموافقة المهندس المشرف، كما يلتزم المقاول بوضع شعارات المنظمة والجهة المانحة على الخزان وفقاً لتوجيهات المهندس المسؤول. يشمل سعر المنتج جميع المواد والعمالة والأدوات والنقل وأي متطلبات أخرى ضرورية للتنفيذ الكامل والسليم للأعمال.
4.2	Excavating work for Base tank & Basin with size 2.6*2.6*0.4m as per directed by AFH engineer.	L.S	1					أعمال الحفر لخزان القاعدة والحوض بأبعاد 0.4*2.6*2.6 متر وفقاً لتوجيهات المهندس المنظمة.
4.3	Stone for Tank Base and Collection Basin Supply and lay a 20 cm thick layer of selected stone for the foundation of the water tank base and the collection basin, covering an area with dimensions of 2.6 m × 2.6 m × 0.20 m. The work shall include proper watering, leveling, and mechanical compaction to achieve the required density and stability, in accordance with approved technical specifications and as directed by the organization's Engineer. The item price shall include all materials, labor, equipment, and any other requirements necessary for the proper execution of the works.	L.S	1					حجر لقاعدة خزان المياه وحوض التجميع توريد وتركيب خنقة من الحجر المختار بسعة ٢٠ سم لقاعدة خزان المياه وحوض التجميع، على مساحة ٢.٦ م × ٢.٦ م × ٠.٢٠ م. يشمل العمل الري والتسوية والضغط الميكانيكي اللازم لتحقيق الكثافة والاستقرار المطلوبين، وفقاً للواصفات الفنية المعتمدة وتوجيه من مهندس المنظمة. يشمل سعر هذا البند جميع المواد والعمالة والمعدات وأي متطلبات أخرى ضرورية لتنفيذ الأعمال على النحو الأمثل.
4.4	Plain Concrete Works for Tank Base Floor Provide and cast plain concrete for the tank base floor with a thickness of 10 cm over an area of 2.6 m × 2.6 m (total volume 0.676 m³), using sulphate-resistant cement. The concrete mix shall consist of 0.8 m³ of coarse aggregate, 0.4 m³ of sand, and 250 kg of cement per cubic meter, achieving a minimum compressive strength of 200 kg/cm². The scope of work shall include surface preparation, formwork (as required), proper mixing, placing, leveling, mechanical compaction (vibration), and curing through adequate watering. All works shall be executed in accordance with the approved specifications, drawings, and the instructions of the organization's Engineer. The rate shall include all materials, labor, equipment, and any other requirements necessary for the complete and proper execution of the works.	L.S	1					أعمال الخرسانة العادية لأرضية قاعدة الخزان توريد وصب الخرسانة العادية لأرضية قاعدة الخزان بسعة ١٠ سم على مساحة ٢.٦ م × ٢.٦ م (حجم إجمالي ٠.٦٧٦ م³)، باستخدام أسمنت مقاوم للكبريتات. يتكون خليط الخرسانة من ٠.٨ م³ من الركام الخشن، و ٠.٤ م³ من الرمل، و ٢٥٠ كجم من الأسمنت لكل م³. لتحقيق مقاومة ضغط لا تقل عن ٢٠٠ كجم/سم². يشمل نطاق العمل تجهيز السطح، والتوالب (حسب الحاجة)، والخلط الجيد، والصب، والتسوية، والدمك الميكانيكي (بالاهزاز)، والمعالجة من خلال الري الكافي. يجب تنفيذ جميع الأعمال وفقاً للواصفات والرسوم المعتمدة، وتعليمات مهندس المنظمة. يشمل السعر جميع المواد والعمالة والمعدات وأي متطلبات أخرى ضرورية لإتمام الأعمال على أكمل وجه.

BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ, YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
4.5	Construction of Concrete Block Walls for Tank and Filling Basin Construct walls using solid concrete blocks with a minimum compressive strength of 35 kg/cm² for the tank enclosure and filling basin, with overall dimensions of 2.6 m × 2.6 m × 1.6 m and a wall thickness of 20 cm. Blocks shall be laid using cement mortar with a mix ratio of 1:3 (cement:sand), utilizing sulphate-resistant cement. The construction shall be executed in a stepped (staggered) manner to ensure proper bonding and structural integrity. The scope of work shall include: Ensuring full interlocking and proper alignment of blocks. Curing of masonry by continuous watering for a minimum period of 7 days. Construction of two internal partition walls using solid stone masonry, each 2.0 m in length, as per drawings. Backfilling inside the base using layers of medium-graded gravel mixed with cohesive soil, sprayed with water and well compacted to achieve the required density. All works shall be carried out in accordance with approved drawings, technical specifications, and the instructions of the supervising Engineering Officer. The rate shall include all materials, labor, tools, and any other requirements necessary for the complete execution of the works.	m ²	22					إنشاء جدران من الب্লوك الخرساني لخزان وحوض تعبئة يبنى جدران من الب্লوك الخرساني الصلب، بمقاومة ضغط لا تقل عن 35 كجم/سم²، لخزان وحوض التعبئة، بأبعاد إجمالية 2.6 × 2.6 × 1.6 م وبسمكة 20 سم. يؤرض الب্লوك باستخدام مونة أسمنتية بنسبة خلط 1:3 (أسمنت:رمل)، مع استخدام أسمنت مقاوم للكبريتات. يُنفذ البناء على مراحل (متداخلة) لضمان التماسك الجيد والسلامة الإنشائية. يشمل نطاق العمل ما يلي: ضمان التعتيق الكامل والمحاذاة الصحيحة للب্লوك. معالجة البناء بالري المستمر لمدة لا تقل عن 7 أيام. بناء جدارين فاصلين داخليين من الحجر الصلب، بطول 2.0 م لكل منهما، وفقاً للرسومات. يتم ردم القاعدة باستخدام طبقات من الحصى متوسط الحجم المخلوط بتراب متماسكة، ثم تُرش بالماء وتُكثف جيداً للوصول إلى الكثافة المطلوبة. تُنفذ جميع الأعمال وفقاً للرسومات المعتمدة والمواصفات الفنية وتعليمات المهندس المشرف. يشمل السعر جميع المواد والعمالة والأدوات وأي متطلبات أخرى ضرورية لإتمام الأعمال. الكمية للموقعين
4.6	Cement Plastering and External Painting Works for Tank Base and Filling Basin Provide and apply cement plastering to all internal and external surfaces of the tank base walls, tank floor, access steps (if applicable), and filling basin, in accordance with approved drawings and specifications. The plastering shall be carried out using cement mortar with a cement content of not less than 300 kg per cubic meter. Plastering work includes two coats (scratch coat and base coat/finishing) with cement mortar at a mixing ratio of (1:2) (cement:sand), with the application of screeds and guides to adjust thickness and straightness, and to obtain a smooth and level surface. The scope of work shall include: Installation of plaster mesh (where required) to prevent cracking and ensure durability. Proper curing by water spraying at least three times daily for a minimum period of five (5) days. Application of high-quality external water-based plastic paint (white color) to all exposed outer surfaces, in two coats. Apply a 20 cm wide border around the base edges on all sides, painted red according to specifications. Printing and fixing the organization's logo on the structure in accordance with the approved format and instructions. All works shall be executed in accordance with the approved drawings, technical specifications, and the directions of the organization's Engineering Officer. The rate shall include all materials, labor, tools, and any other requirements necessary for the complete and proper execution of the works.	M2	25					أعمال التجصيص والطلاء الخارجي لقاعدة الخزان وحوض التعبئة توفير وتطبيق التجصيص الإسمنتي على جميع الأسطح الداخلية والخارجية لجدران قاعدة الخزان، وأرضية الخزان، ودرجات الوصول (إن وجدت)، وحوض التعبئة، وفقاً للرسومات والمواصفات المعتمدة. يتم التجصيص باستخدام مونة إسمنتية لا يقل محتوى الإسمنت فيها عن 300 كجم/م³. تشمل أعمال التجصيص طبقتين (طبقة خشنة وطبقة أساسية/نهائية) باستخدام مونة إسمنتية بنسبة خلط 1:2 (أسمنت:رمل)، مع استخدام أدوات التسوية والتوجيه لضبط السماكة والاستقامة، والحصول على سطح أملس ومستو. يشمل نطاق العمل ما يلي: تركيب شبكة التجصيص (عند الحاجة) لمنع التشققات وضمان المتانة. المعالجة المناسبة بالرش بالماء ثلاث مرات يومياً على الأقل لمدة خمسة (5) أيام على الأقل. تطبيق طلاء بلاستيكي خارجي عالي الجودة ذي أساس مائي (لون أبيض) على جميع الأسطح الخارجية المكشوفة، على طبقتين. تم بتطبيق إطار بعرض ٢٠ سم حول حواف القاعدة من جميع الجوانب، مطلياً باللون الأحمر وفقاً للمواصفات. طباعة شعار المنظمة وتثبيتها على الهيكل وفقاً للتصاميم والتعليمات المعتمدة. يجب تنفيذ جميع الأعمال وفقاً للرسومات والمواصفات الفنية المعتمدة، وتوجيهات مهندس المنظمة. يشمل السعر جميع المواد والعمالة والأدوات وأي متطلبات أخرى ضرورية لإتمام الأعمال على أكمل وجه.
4.7	Supply & construction work of ceramic with Suitable Size by Cement Mortar mixing ratio (1:3), with spraying & filling the joint with white cement as per directed by AFH Engineer.	m2	14					توريد وتركيب السيراميك بالمقاس المناسب باستخدام مونة أسمنتية بنسبة خلط 1:3، مع رش وملء الفراغات بالأسمنت الأبيض وفقاً لتوجيهات مهندس شركة AFH الكمية المطلوبة لموقعين.
4.8	Painting Works (Moisture-Resistant Granular Plastic Finish) Supply and apply high-quality, moisture-resistant granular plastic paint (spray-applied, American type or equivalent) to all external surfaces of the base, tank structure, access steps (if applicable), and filling basin, in accordance with approved specifications. The scope of work shall include: Thorough surface preparation, including cleaning, removal of loose materials, repair of cracks, and treatment of any peeling areas to ensure a sound substrate. Application of two coats of moisture-resistant emulsion primer (base coat), with proper sanding between coats to achieve a smooth and uniform surface. Application of spray-applied granular plastic finish in the approved color, consisting of not less than three coats, using appropriate spraying equipment to ensure a consistent, dense, and homogeneous texture. Ensuring the final finish provides a durable, weather-resistant protective layer to maintain color stability and surface integrity under environmental conditions. All materials and paint types shall be of high quality and subject to prior approval by the organization's Engineer before commencement of works. Mock-up samples shall be submitted for approval as required. The execution shall ensure uniform spray distribution, proper adhesion to the base layer, and a high-quality finish free from defects. The rate shall include all materials, labor, equipment, surface preparation, and any other requirements necessary for the complete and proper execution of the works, in accordance with the instructions of the organization's Engineer.	m2	25					أعمال الطلاء (طلاء بلاستيكي حبيبي مقاوم للرطوبة) توريد وتطبيق طلاء بلاستيكي حبيبي عالي الجودة ومقاوم للرطوبة (رش، من النوع الأمريكي أو ما يعادله) على جميع الأسطح الخارجية للقاعدة، وهيكل الخزان، ودرجات الوصول (إن وجدت)، وحوض التعبئة، وفقاً للمواصفات المعتمدة. يشمل نطاق العمل ما يلي: تحضير السطح بدقة، بما في ذلك التنظيف، وإزالة المواد السائبة، وإصلاح الشقوق، ومعالجة أي مناطق متقشرة لضمان سطح متين. تطبيق طبقتين من برايمر مستحلب مقاوم للرطوبة (الطبقة الأساسية)، مع الصنفرة المناسبة بين الطبقات للحصول على سطح أملس ومتجانس. تطبيق طلاء بلاستيكي حبيبي بالرش باللون المعتمد، يتكون من ثلاث طبقات على الأقل، باستخدام معدات رش مناسبة لضمان ملئ متجانس وكثيف. ضمان أن يوفر الطلاء النهائي طبقة حماية متينة ومقاومة للعوامل الجوية للحفاظ على ثابت اللون وسلامة السطح في مختلف الظروف البيئية. ضمان أن يوفر الطلاء النهائي طبقة واقية متينة ومقاومة للعوامل الجوية للحفاظ على ثابت اللون وسلامة السطح في مختلف الظروف البيئية. يجب أن تكون جميع المواد وأنواع الدهانات عالية الجودة، وأن تخضع لموافقة مسبقة من مهندس المؤسسة قبل بدء العمل. ويجب تقديم عينات تجريبية للموافقة عليها حسب الحاجة. يجب أن يضمن التنفيذ توزيعاً متجانساً للرش، والتصاقاً جيداً بالطبقة الأساسية، وتثبيتاً عالي الجودة خالياً من العيوب. يشمل السعر جميع المواد والعمالة والمعدات وتحضير السطح وأي متطلبات أخرى ضرورية لإتمام العمل على أكمل وجه وبشكل صحيح، وفقاً لتوجيهات مهندس المنظمة.

BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ, YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	
								ملاحظات هامة: أعمال رصف المشاة حول نقطة المياه (العرش: 1.20 متر) توفير وإنشاء رصف المشاة حول نقطة المياه بعرض إجمالي 1.20 متر، وفقاً للرسومات والمواصفات المعتمدة، وتعليمات مهندس المنظمة. تشمل الأعمال المكونات التالية: 1. إنشاء حواجز خرسانية (حوائط): توريد وإنشاء حاجز خرساني متصل (حافة) بارتفاع لا يقل عن 30 سم وقوة ضغط لا تقل عن 300 كجم/سم ² حول المنطقة المحددة. يتم تركيب الحاجز باستخدام مونة اسمنتية بنسبة خلط 1:3 (اسمنت:رمل). يشمل نطاق العمل ما يلي: الحفر إلى العمق المطلوب وإعداد الأساس. وضع طبقة أساسية باستخدام الركام المجري أو الخرسانة المعزية (1:2:4) كإسناد للحوائط. المعالجة والتسوية والتركيب الصحيح للصحيح للحوائط. المعالجة بالتراب بالماء مرتين يومياً على الأقل لمدة سبعة (7) أيام على الأقل. استخدام الأسمنت المقادير للكثافات عند الانتهاء. تنظيف ودهان حواف الأرصفة بالألوان المعتمدة من ثلاثة جوانب، وفقاً لتوجيهات المهندس. 2. أعمال رصف البلاط المشابهة: توريد وتركيب بلاط رصف خرساني متشابه ملون (يفضل النوع ذو الشكل الخواوي أو ما يعقله) بقوة ضغط لا تقل عن 300 كجم/سم ² للمنطقة المرصوفة. يشمل نطاق العمل ما يلي: تحضير الطبقة التحتية، بما في ذلك التسوية، والردم بمواد مناسبة، والري المناسب لتحقيق الكثافة المطلوبة. تركيب البلاط المتشابه وفقاً للضغط والمخانة المعتمدتين. ملء الفواصل وتنظيفها لضمان الثبات والمظهر الموحد. المعالجة النهائية بالتراب بالماء مرتين يومياً على الأقل لمدة خمسة (5) أيام على الأقل. يجب تنفيذ جميع الأعمال وفقاً للمواصفات المعتمدة وتعليمات مهندس AFH. يشمل السعر جميع المواد والعمالة والمعدات وأي متطلبات أخرى ضرورية لتنفيذ الكمال والسليم للأعمال.
4.9	Sidewalk Works Around Water Point (Width: 1.20 m) Provide and construct a sidewalk around the water point with a total width of 1.20 m, in accordance with approved drawings, specifications, and the instructions of the organization's Engineer. The works shall include the following components: 1. Construction of Concrete Curbs (Edge Restraints): Supply and construct a continuous concrete curb (edge beam) with a minimum height of 30 cm and a compressive strength not less than 300 kg/cm ² around the designated area. The curb shall be installed using cement mortar with a mix ratio of (1:3) (cement:sand). The scope shall include: Excavation to the required depth and preparation of the foundation. Placement of a base layer using stone masonry or plain concrete (1:2:4) as a foundation for the curbs. Proper alignment, leveling, and installation of curbs. Curing by water spraying at least twice daily for a minimum of seven (7) days. Use of sulphate-resistant cement where applicable. Finishing and painting of curbs in approved colors on three sides, as directed by the Engineer. 2. Interlocking Tile Pavement Works: Supply and install colored interlocking concrete paving tiles (preferably honeycomb type or equivalent) with a minimum compressive strength of 300 kg/cm ² for the sidewalk area. The scope shall include: Subgrade preparation, including leveling, backfilling with suitable material, compaction, and proper watering to achieve the required density. Installation of interlocking tiles in the approved pattern and alignment. Joint filling and finishing to ensure stability and uniform appearance. Final curing by water spraying at least twice daily for a minimum of five (5) days. All works shall be executed in accordance with approved specifications and the instructions of the AFH Engineer. The rate shall include all materials, labor, equipment, and any other requirements necessary for the complete and proper execution of the works.	m2	22					
4.1	The work of sunshade of corrugated zink (No 2).with 1.5m wide and 2.5 m long with 2 columns, base 0.25 * 0.25m with height 0.2 m and frame of tube 2*4cm for the sunshade as per directed by WASH Engineering Officer.	No	2					مبلة من الزنك المورج بعرض 1.5 متر وطول 2.5 متر مع عوارض قاعدة 0.25 × 0.25 متر بارتفاع 0.2 متر وإطار من الأنابيب 2 × 4 سم للمنطقة وفقاً لتوجيهات مهندس المياه والصرف الصحي.
4	Pipes and Fittings							الأنابيب والملحقات
4.1	Supply and installation of high density polyethylene pipes PE-100 pressure 16 bar according to German specifications DIN8074 - ISO4427 Black Color SDR 11 pipe in Coil of 100m diameter 2.5 inches (63 mm) pressure 16 bar according to international specifications with provision of all necessary special fittings from installing tees and valves to be installed in the places specified by the organization engineer and connection and the work includes providing everything required for the work to carry out excavation and backfilling of polyethylene pipes of all diameters with a depth of 60 cm and a width of 40 cm in the places specified by the supervising engineer by hand drilling and if there is difficulty in the excavation work, concrete supports are built for the rocky places and the work includes providing connecting the pipes through heated by using a butt welding and everything required for the work to be implemented and according to the instructions of the supervising engineer and according to the technical for the installation.	L.M	600					توريد وتركيب أنابيب البولي إيثيلين عالية الكثافة PE-100 بضغط 16 بار وفقاً للمواصفات الألمانية ISO4427 - DIN8074 باللون الأسود. SDR 11. أنبوب مغلف بطول 100 متر وقطر 2.0 بوصة بضغط 16 بار وفقاً للمواصفات الدولية. مع توفير جميع التجهيزات الخاصة للآراء، بما في ذلك تركيب وصلة T والمواصفات في الأماكن التي يحددها مهندس المنظمة، والتوصيل. يشمل العمل توفير كل ما يلزم لتنفيذ أعمال الحفر ودرم الأنابيب الدولي إيثيلين بجميع المقاطر، بمق 60 سم وعرض 40 سم في المواقع التي يحددها المهندس المشرف، وذلك عن طريق الحفر اليدوي. في حال وجود صعوبة في أعمال الحفر، يتم بناء دعائم خرسانية للمواقع الصخرية. يشمل البند البند السق الحراري بين الموسر وبوصل الحرارة والتمام وتوفير كل ما يلزم لتنفيذ العمل وفقاً لتعليمات المهندس المشرف والمواصفات الفنية للتركيب.
4.2	Supplying and installing 16 bar pressure D.I Gate valves according to German specifications DIN8074 - ISO4427, diameter 2.5 inches (63 mm) with all necessary accessories to be installed in the places specified by the organization engineer and the connection and work includes providing everything required for the work to carry out the excavation and backfilling for the connections for all diameters with a depth of 60 cm and a width of 40 cm in the places specified by the supervising engineer by hand drilling. If there is difficulty in the excavation work, concrete supports are built for the rocky places. The work includes providing everything required for the work to be implemented and according to the instructions of the supervising engineer and according to the technical drawings for the installation.	No.	2					توريد وتركيب صمامات بوابة من الحديد الزهر بضغط 16 بار، وفقاً للمواصفات الألمانية ISO4427 - DIN8074، بقطر 2.5 بوصة (63 مم)، مع جميع الملحقات اللازمة، في المواقع التي يحددها مهندس المنظمة. يشمل العمل توفير جميع المستلزمات اللازمة لتنفيذ أعمال الحفر والردم للوصلات بجميع المقاطر، بمق 60 سم وعرض 40 سم، في المواقع التي يحددها المهندس المشرف، وذلك عن طريق الحفر اليدوي. في حال وجود صعوبة في أعمال الحفر، يتم بناء دعائم خرسانية للمواقع الصخرية. يشمل العمل توفير جميع المستلزمات اللازمة لتنفيذ، وفقاً لتعليمات المهندس المشرف والرسومات الفنية للتركيب.
4.3	Supply and installation of high quality gate valve HPDE 2 inches PN 16 in the beginig of each pumping line, with the required and necessary accessories to instal the valves according to the instruction of the engineer.	No.	2					توريد وتركيب صمام بوابة عالي الجودة بولي إيثيلين 2 بوصة PN 16 في بداية كل خط ضخ، مع الملحقات المطلوبة والضرورية لتركيب واتمام العمل وفقاً لتعليمات المهندس.
5.3	Supply and installation of high quality T joint HDPE 2 inches PN 16 for distribute the pumping lines, with the required and necessary accessories to instal the joint according to the instruction of the engineer.	No.	1					توريد وتركيب وصلة T عالية الجودة من البولي إيثيلين عالي الكثافة مقاس 2 بوصة PN 16 لتوزيع خطوط الضخ، مع الملحقات المطلوبة والضرورية لتركيب الوصلة وفقاً لتعليمات المهندس.
4.4	Supplying and implementing of Manhole dimensions (60 × 60 × 50) cm according to the specification and guidance of the supervisor the item include plain concrete for the floor with a thickness of 10 cm and a mixing ratio of (1:2:4) using sulphate-resistant cement, Building solid blocks with cement mortar (1:3) using sulphate-resistant cement, Internal and external plastering, supplying and installing a 3 mm thick iron cover with hinges, locks and painting with two layers of anti-rust paint and two layers of a suitable color determined by the supervising engineer.	No	1					توريد وتركيب فتحات تفريش بأبعاد (60 × 60 × 50) سم وفقاً لمواصفات وتوجيهات المشرف والبند يشمل خرسانة عالية للأرضية بسك 10 سم ونسبة خلط (1:2:4) باستخدام أسمنت مقوم للكثريات، بناء كتل صلبة بمونة اسمنتية (1:3) باستخدام أسمنت مقوم للكثريات، أعمال التجصيص الداخلية والخارجية، توريد وتركيب غطاء حديدي بسك 3 مم مع مفصلات وأقفال وطلاء بطبقتين من الطلاء المقوم للصدأ ومطبقين من لون مناسب يحدده المهندس المشرف.
5	Project Introductory Signboard							لوحات تعريفية بالمشروع



BILL OF QUANTITY OF SAFE WATER ACCESS AND COMMUNITY HEALTH PROMOTION IN
WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ,YEMEN

13°15'28.3"N 44°33'03.9"E

Item No	Item Details	Unit	Qty	Brand	Origin	Unit Price	Total Cost	تفاصيل البند
	Important Note:					USD \$	USD \$	ملاحظات هامة:
5.1	A marble identification board for the project with the dimensions specified by the supervising engineer with the organization's logo and stating (the name of the project, the funding body, the supervising body, the supplying company, the type of work that was supplied and installed) so that it is installed in the specified location according to the instructions of the supervising engineer. with a size of 40 cm * 40 cm to be fixed in the location specified by the organization's engineer.	L.S	1					لوحة تعريفية وخامية للمشروع، بأبعاد يحددها المهندس المشرف، تحمل شعار المؤسسة، وتتضمن (اسم المشروع، والجهة الممولة، والجهة المشرفة، والشركة الموردة، ونوع العمل الذي تم توريده وتركيبه)، بحيث يتم تركيبها في الموقع المحدد وفقاً لتعليمات المهندس المشرف. مغلن اللوحة 40 سم × 40 سم، ويتم تثبيتها في الموقع الذي يحدده مهندس المؤسسة.
6.00	Supply & Installation of Solar Street Lighting Units Supply, install, test, and commission solar-powered street lighting units for illumination of the solar panels' courtyard, complete with all required accessories and civil works, in accordance with the following specifications and as directed by the AFH Engineer: Solar Panel Rated capacity: minimum 60 W. Nominal voltage: 18 V. High-efficiency module suitable for outdoor use under high temperatures. Battery & Control System Lithium battery, nominal voltage 12.6 V. Integrated light sensor (dusk-to-dawn operation) and motion sensor. Battery and panel capacity shall be sufficient to operate the lamp for not less than 12 hours continuously. Lighting Unit (LED Luminaire) Luminous efficacy: not less than 100 lumens/Watt. Color temperature: 3000K–5000K. Minimum lifespan: 30,000 operating hours. Protection rating: IP65 or higher (dustproof and waterproof). Operating temperature: suitable for ambient conditions up to 60°C. Standards & Certifications All shall comply with recognized international standards and include certifications such as CE, RoHS, or equivalent. Lighting Pole Material: Galvanized iron pipe. Diameter: 3 inches. Thickness: minimum 4 mm. Height: 3.0 m above ground level. The pole shall be coated with: Anti-rust primer. Final paint layers in color approved by the Engineer. Foundation The pole shall be fixed in a concrete foundation (30 × 30 × 30 cm) using concrete mix ratio 1:2:4. Proper alignment and verticality shall be ensured during installation.	No.	1					توريد وتركيب وحدات إنارة الشوارع بالطاقة الشمسية توريد وتركيب واختبار وتشغيل وحدات إنارة الشوارع التي تعمل بالطاقة الشمسية لإضاءة ساحة الألواح الشمسية، مع جميع الملحقات والأعمال المدنية اللازمة، وفقاً للمواصفات التالية ويتوجب من مهندس شركة AFH: اللوحة الشمسية القدرة المقرة: 60 واط كحد أدنى. الجهد الاسمي: 18 فولت. وحدة عالية الكفاءة مناسبة للاستخدام الخارجي في درجات الحرارة المرتفعة. البطارية ونظام التحكم بطارية ليثيوم، الجهد الاسمي 12.6 فولت. مستشعر حركي مدمج (يعمل من الفسق إلى الفجر) ومستشعر حركة. يجب أن تكون سعة البطارية واللوحة كافية لتشغيل المصباح لمدة لا تقل عن 12 ساعة متواصلة. وحدة الإضاءة (مصباح LED) الكفاءة الضوئية: لا تقل عن 100 لومن/واط. درجة حرارة اللون: 3000-5000 كلفن. العمر الافتراضي الأدنى: 30000 ساعة تشغيل. مستوى الحماية: IP65 أو أعلى (مقاوم للغبار والماء). درجة حرارة التشغيل: مناسبة للظروف المحيطة حتى 60 درجة مئوية. المعايير والشهادات يجب أن تتوافق جميعها مع المعايير الدولية المعترف بها، وأن تشمل شهادات مثل CE أو RoHS أو ما يعادلها. نموذ الأنارة المادة: أنبوب حديد مجلفن. القطر: 3 بوصات. السمك: 4 سم كحد أدنى. الارتفاع: 3 أمتار فوق مستوى سطح الأرض. يجب طلاء العمود بما يلي: طبقة أساسية مضادة للصدأ. طبقات طلاء نهائية بلون معتمد من قبل المهندس. الأساس يجب تثبيت العمود في أساس خرساني (30 × 30 × 30 سم) باستخدام خلطة خرسانية بنسبة 1:2:4. يجب ضمان المحاذاة الصحيحة والاستقامة الرأسية أثناء التركيب.
GRAND TOTAL COST OF WADI THAR WATER PROJECT, AL-QABBAYTAH, LAHJ								اجمالي التكلفة لمشروع مياه وادي ثار مديرية القبيطة، م/ لحج
% of Discount if any								نسبة التخفيض إن وجدت %
GRAND TOTAL AFTER DISCOUNT								الاجمالي الكلي بعد التخفيض